

Approval Number 1809539
Test Report: MA7374/U, MA6444/Y, MA6567/R & MA7099/F



4th November 2021

Rich. Klinger Dichtungstechnik GmbH & Co. KG
Am Kanal 8-10
A - 2352 Gumpoldskirchen
Austria

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

'KLINGERSIL® C-4430'. Calandered NBR/fibre gasket material which is green coloured on one side and white coloured on the other. For use with water up to 85°C.

APPROVAL NUMBER: 1809539

APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO. KG

The Scheme reserves the right to review approval.
Approval 1809539 is valid between September 2018 and September 2023

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', written over a horizontal line.

Ian Hughes
WRAS Approvals Manager