

Approval Number 1909503
Test Report: MA6444/Y & MA7374/U



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

2nd August 2022

Rich. Klinger Dichtungstechnik GmbH & Co. KG
Am Kanal 8-10,
A - 2352 Gumpoldskirchen,
Austria

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

'KLINGERSIL® C-4430'. NBR/fibre gasket material, which is green coloured one side and white coloured the other, manufactured by calendering.

Between September 2019 and September 2021, the material is for use with water up to 23°C.
Between October 2021 and September 2024, the material is for use with water up to 85°C.

For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 1909503
APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO. KG

This is a re-approval of 1408541 which is valid between August 2014 and August 2019.

The Scheme reserves the right to review approval.
Approval 1909503 is valid between September 2019 and September 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager